Grog Shop 2296 Santa Rosa Avenue Santa Rosa 1TSR298

Notice of Proposed No Further Action related to petroleum discharges. Comment Period ends December 11, 2001.

Problem Description: Three gasoline underground storage tanks were removed from 2296 Santa Rosa Avenue in August 1995. Visually impacted soil was observed beneath the tanks, which contained total petroleum hydrocarbons as gasoline at up to 2.3 parts per billion. The area of impact was limited and removed at the time of tank removal. A waste oil tank was previously removed from the property. In 1997, visually impacted soil was removed.

Interim Actions Completed. A groundwater investigation was conducted in March 1999. Nine soil borings were drilled in the vicinity of the former tanks, piping and dispensers. Soil samples were collected from the borings and no detectable levels of petroleum hydrocarbons were reported. Groundwater was encountered between 9 and 18 feet below ground surface. Groundwater samples contained no detectable levels of petroleum hydrocarbons, chlorinated hydrocarbons or gasoline oxygenates, except for TPHg at 105, benzene at .87, toluene at .58 parts per billion (ug/l), ethylbenzene at 1.6 and xylene at 2.2 ug/l in one boring. An unidentified petroleum hydrocarbon was also detected at 117 ug/l.

MtBE Status: None Present

Case Closure with no further action will be completed without further notice unless significant public comment is received prior to December 11, 2001. Please contact Joan Fleck at (707) 576-2675 or Fleci@rb1.ca.gov.

JEF:js/grogshopweb